## PRAKASH ASSOCIATES

ARCHITECT, CONSULTING STRUCTURAL ENGINEER, GOVT. REGISTERED VALUER B-2/2, Sector 18, ROHINI, DELHI-110089. Ph: 011-35745843, (M) : 09868109216 E-mail : vermaprakash10@yahoo.co.in

PRAKASH VERMA Structural Engineer MCD License SE-02

Date: 10.05.2023

## STRUCTURE STABILITY CERTIFICATE

I personally inspected Sachdeva Public School, Maurya Enclave, Pitampura, Delhi on 10.05.2023

There are two block 1 & 2. Block 1 : Basement , Ground , First & Second floor. Block 2 : Ground Floor and First Floor.

The building structure has 9" brickwork load bearing wall with RCC components – beams, columns and roof.

The structure has no cracks and is of good quality.

The structure is presently in good condition and is safe & sound for school purpose.

No structural changes should be done in the complete block structure without the advice & supervision of an engineer.

Pakers Hours

STRUCTURAL ENGINEER PRATAVEL VERMEN Structurel 1 (2000) M.G.D. Licenso No. 5 (20) 0-2/2, Stord, Rohme Failti

RASTOGI) (MON Principal Sechdeva Public School (Recognized) Maurya Enclave, Pitata Pure, A Delt.i-110066