



DELHI TEST HOUSE[®]

(A Unit of Delhi Test House Global LLP)

A-62/3, G.T. Karnal Road, Industrial Area, Near Metro Pillar No. 600, Azadpur, Delhi-110 033 (INDIA)
Ph. : +91-11-47075555 (30Lines) E-mail : info@delhitesthouse.com

Website : www.delhitesthouse.com



TC-14461

Report No.: WT250619001
Report Date: 26-Jun-2025
ULR No.: TC1446125000028899F

TEST REPORT

Report Issued To :	Sample Received On	Analysis Duration	
		Start Date	End Date
-	19-Jun-2025	19-Jun-2025	25-Jun-2025
SACHDEVA PUBLIC SCHOOL MAURYA ENCLAVE, FP BLOCK, PITAMPURA, DELHI - 110088, DELHI, Delhi, 110088			

Sample Description :-

Sample Name : R.O WATER
Test Reference : ESSENTIAL TEST AS PER IS:10500-2012
Sample Quantity : 2 LTR+250 ML
Letter Dated : 17.06.2025
Marks : THE SAMPLE WAS COLLECTED BY MR. JOGINDER DELHI TEST HOUSE REPRESENTATIVE NAME & ADDRESS OF THE UNIT- SACHDEVA PUBLIC SCHOOL, MAURYA ENCLAVE , FP BLOCK, PITAMPURA DELHI - 110088

Test Results :

Sr.No	Specific Test	Units	Acceptable Limits	Result	Permissible Limits	Test Method
Discipline : CHEMICAL						
Main Group : Water						
Table-1, Organoleptic and Physical Parameter (Clause 4)						
1	Colour	Hazen Unit	Max 5	<2	Max. 15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7 & 8)
4	Turbidity	NTU	Max. 1	<1	Max. 5	IS 3025 (P-10)
5	pH Value	-	6.5 to 8.5	7.17	No Relaxation	IS 3025 (P-11)
6	Total Dissolved Solids	mg/l	Max 500	152	Max. 2000	IS 3025 (P-16)
Table-2, General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)						
1	Total Hardness (as CaCO ₃)	mg/l	Max 200	50.5	Max. 600	IS 3025 (P-21)
2	Chloride (as Cl)	mg/l	Max. 250	21.2	Max. 1000	IS 3025 (P-32)
3	Fluoride (as F)	mg/l	Max. 1.0	<0.2	Max. 1.5	APHA.4500F' 24th Edition

Reviewed By

Aj
AJAY KUMAR SINGH
SR. ANALYST

Authorised By

Suman
SUMAN KUMAR JHA
QUALITY MANAGER
Signatory - Director

M.C. GOEL



DELHI TEST HOUSE[®]

(A Unit of Delhi Test House Global LLP)

A-62/3, G.T. Karnal Road, Industrial Area, Near Metro Pillar No. 600, Azadpur, Delhi-110 033 (INDIA)

Ph. : +91-11-47075555 (30Lines) E-mail : info@delhitesthouse.com

Website : www.delhitesthouse.com



Report No.: WT250619001
 Report Date: 26-Jun-2025
 ULR No.: TC1446125000028899F

TEST REPORT

Sr.No	Specific Test	Units	LOQ	Acceptable Limits	Result	Permissible Limits	Test Method
Discipline : BIOLOGICAL							
Main Group : WATER							
Bacteriological test as per Table 6 Clause 4.1.1							
1	Total coliform bacteria	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185
2	E. coli	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185
Discipline : CHEMICAL							
Main Group : Residues in Water							
Table-2, General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)							
1	Iron (as Fe)	mg/l	0.001	Max. 1	BLQ	No Relaxation	IS 3025 (P-65)

BLQ - Below Limit of Quantification
 LOQ - Limit of Quantification

Remarks : The sample conforms to IS 10500:2012 with respect to the above test only.

Note : 1. No Deviation from the Standard Test Method/ Specification is done unless specified or requested by the client.
 2. While giving the conformity statement laboratory does not consider Uncertainty Measurement into account.
 3. General terms & Conditions are given on the back side of the report.



NABL Scope

***** End Of Report *****



Report

Reviewed By

Ajay
 AJAY KUMAR SINGH
 SR. ANALYST


Authorised By

Suman
 SUMAN KUMAR JHA
 QUALITY MANAGER

M. GOEL
 M. GOEL
 Director



MUNICIPAL CORPORATION OF DELHI
(Office of the Deputy Health Officer)
Public Health Department : Keshav Puram Zone
A-1 Block, Keshav Puram, New Delhi
E-mail : keshavpuramdho@gmail.com



No. DHO/KPZ/2022/ 2270

Dated:- 14-12-22

The Principal
Sachdeva Public School,
Maurya Enclave, Pitampura,
Delhi-110088.


SCHOOL HEALTH CERTIFICATE


Date of Inspection	:	13/12/2022
Name of the School	:	Sachdeva Public School
Location	:	Maurya Enclave, Pitampura, Delhi-88
Shift & Timing of School	:	Morning (07:40 AM to 02:15 PM)
No. of Students	:	Total - 3207 (Boys -1815 & Girls -1392)
No. of Staff members	:	Total - 168 (Male -24 & Female -144)
No. of Classrooms	:	100
Water-source	:	Tap-water
No. of Urinals	:	42
No. of WC seats	:	32

Inspected the premises and checked the following parameters from health point of view:-

1. That the floor space in the class room is sufficient.
2. That all class-rooms are well ventilated, white washed and well lighted.
3. That the class rooms are kept neat and clean.
4. That the drinking water is wholesome.
5. That the first aid box is also arranged in proper manner.
6. That the latrine arrangement is sanitary and hygienic.

In view of the above submissions, this certificate is being issued by the undersigned for one year from the date of issue in favour of Sachdeva Public School, Maurya Enclave, Pitampura, Delhi-110088, after being fully satisfied and having NO OBJECTION FROM HEALTH POINT OF VIEW.


(MONA RASTOGI)
Principal
Sachdeva Public School (Recognised)
Maurya Enclave, Pitam Pura,
Delhi-110088


Deputy Health Officer
Keshav Puram Zone